NORDIC STRUCTURES

Built-up Column Conversions

Sawn Lumber Built-up Column Conversions to Nordic Lam ES12

Sawn lumber	One side fully braced – for use in stud walls $^{(a)}$		Unbraced ^(b)	
built-up column				
S-P-F or D Fir-L	Bearing on	Bearing on	Bearing on	Bearing on
No. 1/No. 2	other non-wood	sawn lumber	other non-wood	sawn lumber
2 - 2 x 4	3-1/2 x 3-1/2	3-1/2 x 3-1/2	3-1/2 x 3-1/2	3-1/2 x 3-1/2
3 - 2 x 4	3-1/2 x 3-1/2	3-1/2 x 5-1/2	3-1/2 x 3-1/2	3-1/2 x 5-1/2
4 - 2 x 4	3-1/2 x 5-1/2	3-1/2 x 7	3-1/2 x 3-1/2	3-1/2 x 7 ^(c)
5 - 2 x 4	3-1/2 x 5-1/2	-	3-1/2 x 3-1/2	5-1/2 x 5-1/2
2 - 2 x 6	3-1/2 x 5-1/2	3-1/2 x 5-1/2	3-1/2 x 3-1/2	3-1/2 x 5-1/2
3 - 2 x 6	3-1/2 x 5-1/2	5-1/2 x 5-1/2	3-1/2 x 3-1/2	5-1/2 x 5-1/2
4 - 2 x 6	3-1/2 x 5-1/2	5-1/2 x 7	3-1/2 x 5-1/2	5-1/2 x 7
5 - 2 x 6	5-1/2 x 5-1/2	-	3-1/2 x 7 ^(c)	7 x 7
2 - 2 x 8	3-1/2 x 7-1/4	3-1/2 x 7-1/4	3-1/2 x 3-1/2	3-1/2 x 7 ^(c)
3 - 2 x 8	3-1/2 x 7-1/4	5-1/2 x 7-1/4	3-1/2 x 5-1/2	5-1/2 x 7
4 - 2 x 8	3-1/2 x 7-1/4	7 x 7-1/4	3-1/2 x 7 ^(c)	7 x 7
5 - 2 x 8	5-1/2 x 7-1/4	-	3-1/2 x 7 ^(c)	-

a) One side fully braced - Compression members are assumed to be braced in the direction of the wall plane and unbraced in the other direction.

b) Unbraced - Compression members are assumed to be unbraced in both directions.

c) 5-1/2 x 5-1/2 column may also be used.

Notes:

- 1. For preliminary design use only. Final design shall include a complete analysis including the verification of the bearing capacity. Smaller Nordic Lam sections may possibly be used with engineering calculations based on true conditions.
- 2. The table is based on dry service conditions, normal duration of loading, and no treatment.
- 3. The conversions are based on the built-up columns axial capacity, with a maximum length of 10 feet, and subjected to a maximum eccentricity of either 1/6 member width or depth, whichever is worse. Lateral loads are not considered.
- 4. Reverse use of this table is non-conservative in all cases. Refer to NDS 2018 design properties for sawn lumber.
- 5. Built-up compression members are assumed to be fastened together with nails as required by Clause 15.3.3 of the NDS.
- 6. Compression members are assumed to be pinned at their ends.